

Technical data

Terminal boxes (Ex e) BXJ-e-□□

Explosion protection

Gas explosion protection

⊕ II 2 G Ex e IIC T6 or T5 Gb

⊕ II 2 G Ex ib IIC T6 Gb

Dust explosion protection

⊕ II 2 D Ex tb IIIC T80°C Db IP66

Certificates

LCIE 13 ATEX ____; IECEX; GOST.R (Russia); PCEC(China)

Conformity to standards

EN 60079-0:2009, EN 60079-7:2007

EN 60079-11:2007, EN 60079-31:2009

IEC 60079-0:2011, IEC 60079-7:2006

IEC 60079-11:2006, IEC 60079-31:2008

Enclosure material

Copper-free aluminium; powder coated surface

Enclosure colour

Window grey (RAL7040)

Terminal

Weidmuller SAK EN series

Ex-mark: ⊕ II 2 GD Ex e II

Exposed fastener

Stainless steel

Rated voltage

Max. 690V AC

Rated current

Cross section	2.5mm ²	4mm ²	6mm ²	10mm ²	16mm ²	35mm ²
Ex e Rated current	24A	32A	41A	57A	76A	125A
Ex ib Rated current	5A	5A	-	-	-	-

Degree of protection

IP66

Ambient temperature

For increased safety terminal box: T6 for Tamb: -40°C ~ +40°C; T5 for Tamb: -40°C ~ +55°C


For intrinsic safety terminal box: T6 for Tamb: -40°C ~ +55°C

Note

Ex e Rated current > 125A on request

Cable entry table

Table of max. number of possible enclosure entries with cable glands DQM-I












	I		II		III		IV		V		VI		VII		VIII	
	A/B	C/D	A/B	C/D	A/B	C/D	A/B	C/D	A/B	C/D	A/B	C/D	A/B	C/D	A/B	C/D
M20 x 1.5	2	3	4	4	4	6	6	6	6	10	10	10	8	12	12	18
M25 x 1.5	2	3	3	3	3	4	4	4	5	9	9	9	7	10	10	16
M32 x 1.5	1	2	2	2	2	3	3	3	3	4	4	4	4	6	6	10
M40 x 1.5	1	2	2	2	2	3	3	3	2	3	3	3	2	3	3	5
M50 x 1.5	/	/	/	/	/	/	/	/	/	3	3	3	2	3	3	5
M63 x 1.5	/	/	/	/	/	/	/	/	/	2	2	2	2	3	3	4

Note: 1. No cable entries for standard design. Cable entries shall be drilled by user.

2. For cable entries:

1) Please specify the direction and size of each cable entry.

2) Cable gland is optional, DQM-I (Ex e) is recommended. Please see P7/17~19.

Selection table of BXJ-e series terminal boxes								
Max. cross section of cable connected to terminals is 35mm ²								
See table for max. number of fitted terminals								
Cable size (mm ²)		2.5 (a)	4 (b)	6 (c)	10 (d)	16 (e)	35 (f)	Weight
Enclosure code/Ordering code	Outline	SAK 2.5EN	SAK 4EN	SAK 6EN	SAK 10EN	SAK 16EN	SAK 35EN	(kg)
I		16	15	12	10	—	—	2.40
II		16	15	12	10	8	—	2.80
III		25	22	20	15	12	—	3.80
IV		25	22	20	15	12	8	5.10
V		35	30	25	20	15	—	5.80
VI		35	30	25	20	15	10	7.10
		60	50	40	—	—	—	7.50
VII		40	35	30	24	18	12	7.00
		40	40	30	—	—	—	7.00
VIII		60	55	40	30	20	15	9.50
		100	90	66	60	40	—	9.70

